

Health Comments:

ANY NEW ADDITION MUST COMPLY WITH ALL SETBACKS TO THE SEPTIC SYSTEM. NEW SLAB SHALL NOT BE CLOSER THAN 10 FEET TO ANY PORTION OF THE SEPTIC SYSTEM. NEW CELLAR WALL OR CRAWL SPACE SHALL NOT BE CLOSER THAN 20 FEET TO LEACH FIELD.